

Washington County
620 S. 400 E. Suite # 400
St. George, UT 84770
435-673-3528

Iron County
260 E. DL Sargent Dr.
Cedar City, UT 84721
435-586-2437

Beaver County
75 W. 1175 N.
Beaver, UT 84713
435-438-2482

Kane County
245 S. 200 E.
Kanab, UT 84741
435-644-2537

Garfield County
609 N. Main St.
Panguitch, UT 84759
435-676-8800

Requirements For Obtaining A Variance To R392-302-29 (Design, Construction and Operation of Public Pools - Supervision of Pools)

1. A variance only applies to R392-302-29(4)(a) to reduce the minimum number of required pool water tests from four times daily to once daily
 - a. A properly installed and operating oxidation reduction potential controller (ORP) eliminates the need to apply for a variance in order to reduce the frequency of testing
2. A variance is only available to a limited use pool
 - a. A limited use pool is a pool in a planned unit development, home owners association or other non-transient community where:
 - i. Access fees are not charged for the use of the pool
 - ii. Access to the pool is limited to the persons living or residing at the facility and their guests
 - iii. The average daily use of the pool is less than fifty percent(50%) of the pools maximum bather load as determined by R392-302-7
 - b. Owner refers to the individual(s), board, corporation, or other entity having responsibility for the limited use pool facilities
3. Each limited use pool owner must have a contract with a qualified pool operator (QPO), approved under R392-302-29(1), to maintain their pool.
 - a. The QPO must inspect the limited use pool three (3) times each week
 - i. At least one day must pass between each inspection by the QPO
 - ii. No more than two (2) days may pass between each inspection by the QPO
 - b. During each inspection of the limited use pool the QPO shall observe and record the following:

i. Disinfectant residual (free and total)	vii. Filter maintenance
ii. pH	viii. Amounts of chemicals added
iii. Total Alkalinity	ix. Water temperature
iv. Cyanuric Acid	x. Water clarity
v. Calcium hardness	xi. General appearance
vi. Flow gauges	xii. Total number of bathers using the pool.
 - c. Additionally the QPO shall be responsible for ensuring that all other requirements of R392-302 are being met by the limited use pool. The QPO shall report any uncorrected violations to Southwest Utah Public Health Department (SWUPHD)
4. Each limited use pool owner shall be responsible for coordinating with their contracted QPO to develop a pool maintenance plan
 - a. The plan shall be submitted to SWUPHD for approval.
 - b. The QPO, limited use pool representative, and a SWUPHD environmental health scientist must all sign the plan for the plan to be valid.
 - i. The valid plan must be on file at SWUPHD.
 - ii. The limited use pool must maintain a copy of the valid plan at the pool for review.
 - c. The plan shall include current contact information for

i. The ownership of the limited use pool	iii. Designated pool monitoring person(s) for the limited use pool
ii. Any property management company for the limited use pool	iv. The contracted QPO
 - d. The plan shall include
 - i. Type(s) of pool(s) at the limited use pool facility
 - ii. A pool monitoring schedule detailing when the QPO will monitor the pool, and when the limited use pool will be responsible for monitoring the pool.
5. Each limited use pool owner shall designate person(s) who shall be responsible for monitoring the pool(s) on all days that the QPO does not inspect the pool
 - a. The designated pool monitoring person(s) of the limited use pool shall observe and record the following:

i. Disinfectant residual (free)	iv. Water clarity
ii. pH	v. General appearance
iii. Flow gauges	vi. Total number of bathers using the pool
 - b. The designated pool monitoring person(s) of the limited use pool shall notify the QPO immediately of any observed problems.
6. Both the designated pool monitoring person(s) and the QPO shall keep an up to date daily pool log
 - a. This log shall be kept at the limited use pool facility and be readily available for inspection by SWUPHD
7. A variance may be revoked by SWUPHD if the limited use pool does not meet the standards of R392-302 for:

a. Disinfectant residual	e. Alkalinity
b. pH	f. Calcium hardness
c. Water clarity	g. Cyanuric acid
d. Flow rate	

 - h. Failure to review the plan and re-submit changes when
 - i. The contracted QPO changes
 - ii. The designated pool monitoring person(s) for the limited use pool changes
 - iii. The ownership of the limited use pool changes
8. Any limited use pool that does not comply with any portion of these requirements may be required to meet the full current requirements of R392-302-29
9. All pool plans expire on December 31st of the year that the plan is submitted.